

T E S T C E R T I F I C A T E

ST-20-10-01-02

Product: Osmo Country Colour

Manufacturer: Osmo Holz und Color GmbH & Co. KG
Lütkenbecker Weg 12
48155 Münster
Germany

Order: Determination of water vapour diffusion according EN ISO 7783:2019

Test report: 2720130_A1

Test results:

Property	Result	Determined class in accordance with EN 1062-1:2004, Tab. 4
Water vapor diffusion flow density V	216.6 g/(m ² * d)	V1
Diffusion-equivalent air layer thickness s _d	0.11 m	
Water vapor diffusion resistance factor μ	18.5	

Dresden, 01/10/2020



Head of laboratory




Engineer in charge